



BXUV.U349 Fire Resistance Ratings - ANSI/UL 263

[Page Bottom](#)

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Listed or Classified products, equipment, system, devices, and materials.
 - Authorities Having Jurisdiction should be consulted before construction.
 - Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
 - When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
 - Only products which bear UL's Mark are considered as Classified, Listed, or Recognized.
-

Fire Resistance Ratings - ANSI/UL 263

[See General Information for Fire Resistance Ratings - ANSI/UL 263](#)

Design No. U349


July 29, 2010

Bearing Wall Rating — 2 Hr

(EXPOSED TO FIRE ON INTERIOR FACE ONLY)

For Wood Studs, Finish Rating — 55 min

Load Restricted for Canadian Applications — See Guide [BXUVZ](#)



1. Wood Studs — Nom 2 by 4 in., spaced 16 in. OC in with two 2 by 4 top and one 2 by 4 bottom plates. Studs cross-braced at midheight and effectively fire stopped at top and bottom of wall.

1A. Steel Studs — (Not Shown) In lieu of Item 1. Corrosion protected steel studs, min No. 20 MSG and min. 3-1/2 in. deep, cold formed, shall be designed in accordance with the current edition of the Specification for the Design of Cold-Formed Steel Structural Members by the American Iron and Steel Institute. All design details enhancing the structural integrity of the wall assembly, including the axial design load of the studs, shall be as specified by the steel stud designer and/or producer, and shall meet the requirements of all applicable local code agencies. The max stud spacing of wall assemblies shall not exceed 16 in. OC. Studs attached to floor and ceiling tracks with 1/2 in. long Type S-12 steel screws on both sides of studs or by welded or bolted connections designed in accordance with the AISI specifications.

1B. Steel Floor and Ceiling Tracks — (Not Shown, for use with Item 1A) — Top and bottom tracks of wall assemblies shall consist of steel members, min No. 20 MSG and min. 3-1/2 in. deep. Attached to floor and ceiling assemblies with steel fasteners spaced not greater than 24 in. O.C.

1C. Lateral Support Members — (Not shown, for use with Item 1A) — Where required for lateral support of steel studs, support may be provided by means of steel straps, channels or other similar means as specified in the design of a particular steel stud wall system.

2. Gypsum Board* — Any Classified 5/8 in. thick, 4 ft. wide, two layers applied vertically. Base layer nailed to wood studs and bearing plates 6 in. OC. with 6d cement coated nails, 1-7/8 in. long, 0.0915 in. shank diam. and 1/4 in. diam. head. The face layer, with joints staggered from base layer, nailed to the studs and bearing plates over the base layer, 8 in. OC. with 8d cement coated nails, 2-3/8 in. long, 0.113 in. shank diam. 9/32 in. diam. head. For securement to steel studs and track, 1 in. long Type S or S-12 steel screws to be used to install the base layer and 1-5/8 in. long Type S or S-12 steel screws to be used to install the face layer. Spacings of screws that same as described for nails.

See **Gypsum Board*** (CKNX) category for names of Classified manufacturers.

3. Joints and Nailheads — Wallboard joints covered with tape and joint compound. Nail heads covered with joint compound.

4. Batts and Blankets* — Unfaced mineral fiber insulation, 3-1/2 in. thick, nom 3.0 pcf, pressure fit in the wall cavity between stud, plates, and cross bracing.

See **Batts and Blankets*** (BZJZ) category for names of Classified manufacturers.

5. **Building Units*** — Building units nailed to the wood framing with 1-7/8 in. long, 6d nails, spaced 6 in. OC. on the perimeter and 12 in. OC. in the field. When steel studs are used min. 1-7/8 in. long steel screws installed 6 in. OC on the perimeter and 12 in. OC in the field.

BARRIER TECHNOLOGY CORP — Type Blazeguard 2-Side

LOUISIANA-PACIFIC CORP — Type LP FlameBlock 2-Side

6. **Exterior Facings** — Installed in accordance with the manufacturer's Installation Instructions.

6A. **Vinyl Siding*** — (Optional) - UL Classified exterior plastic siding (molded plastic), fastened to the building units with nails or screws, at the locations specified by the manufacturer.

6B. **Particle Board Siding*** — (Optional) - Oriented strand board, wafer board, or hard board exterior building sidings including patterned panels.

6C. **T-1-11 Plywood** — (Optional) - American Plywood Association rated siding series 303 including textures, bough sawn, MDO, brushed, channel grooved, and lap siding.

6D. **Cementitious Stucco** — (Optional) - Portland cement or synthetic stucco systems with self furring metal lath or adhesive base coat. Thickness from 3/8 in. to 3/4 in. depending on system.

*Bearing the UL Classification Mark

Last Updated on 2010-07-29

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2010 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

